

Attachment 2


Vermont Yankee Nuclear Power Station

Proposed Technical Specification Change No. 263 – Supplement No. 9

Extended Power Uprate

Revised Containment Overpressure Envelope

VYC-0808, Revision 6, CCN 06


	VYC-0808, Revision 6, CCN 06		
	ENN-DC-126, Rev 4	MINOR CALCULATION CHANGE	PAGE 1 OF 14

ENN-DC-126, ATTACHMENT 9.8

MINOR CALCULATION CHANGE FORM

MINOR CALCULATION CHANGE FORM (Tracked via DRN in MERLIN)

Calculation No.: VYC-0808		Revision: <u>6</u> <u>Indicate Status of</u> <u>Minor Calculation</u> Change: - Prel: - Pend: - As-Built
Calculation Title: Core Spray and Residual Heat Removal Pump Net Positive Suction Head Margin Following a Loss of Coolant Accident or Anticipated Transient Without Scram		
MERLIN DRN No. or Minor Calculation Change No.: <u>06</u>		
Modification No./Task No./ER No. <u>VYDC-2003-008</u>		
Computer Code Used <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No. If "Yes", Code: _____		
1 Purpose of Change:	Incorporate GE-VYNPS-AEP-346R1	
2 SSC affected:	See attached VYAPF0017.07	
3 Design Input Documents not used in parent Calculation:	See attached VYAPF0017.07	
4 Drawings/Procedures/ Calculations / other Documents affected	See attached VYAPF0017.07	
5 Description of Change:	See attached description	
6 Impact on existing calculation conclusion:	Revised containment overpressure envelope for long term LOCA using 100% Spray Efficiency	
7 Impact on DBD's, UFSAR, Technical Specifications:	See attached VYAPF0017.07	
8. The existing calculation does/does not (circle one) have a calculation verification checklist. (See Remarks)		
Remarks: This ENN-DC-126 MCC is to a VY design verified calculation prepared under AP-0017. AP-0017 did not have a "checklist", instead design verification was documented on form VYAPF0017.04		
NOTE:		
A. If UFSAR or Technical Specifications need to be revised, Minor Calculation Change Form should not be used unless it is an editorial change to the UFSAR or Technical Specifications.		
B. Minor Calculation Change Forms do not change the status of the Parent Calculation Revision.		
Prepared by:	E. P. O'Brien <i>E. P. O'Brien</i>	Date: 7/16/04
Reviewed by: *	E.G. Lind <i>E. G. Lind</i>	Date: 7/16/04
Approved by	D.E. Yasi <i>D. E. Yasi</i>	Date: 7/20/04
* Where the original calculation was design verified, the reviewer signature confirms the latest design verification is still valid.		
This IS a Quality Record -		

	VYC-0808, Revision 6, CCN 06	
	ENN-DC-126, Rev 4	PAGE 2 OF 14

ENN-DC-126, REV. 4, ATTACHMENT 9.8

MINOR CALCULATION CHANGE FORM

5. Description of Change

The NPSH evaluation of the RHR and CS pumps is performed, using the same methodology as CCN04 (Ref. 11) for short term DBA-Loss of Coolant Accident (LOCA) case and CCN05 (Ref. 12) for long term DBA-Loss of Coolant Accident (LOCA) case. This CCN uses the EPU suppression pool temperature/pressure data supplied in Reference 1. Note – all References contained in AP0017.07 (Attachment B)

Reason for Change:

This CCN provides additional results regarding the Residual Heat Removal (RHR) and Core Spray (CS) Pump NPSH resulting from the Extended Power Uprate (EPU), which was initially evaluated in CCN04 and subsequently in CCN05.

Specifically, this CCN06 updates the short-term and long-term post LOCA results based on revised containment temperature and pressure profiles provided in Reference 1. The revised containment profiles reflect that the Containment Spray Thermal Mixing Efficiency used to develop the Reference 1 input was increased to 100%. This increase in spray efficiency resulted in a slight reduction to the pressure profile. The containment spray thermal mixing efficiency utilized in CCN 5 was based on the containment air to steam mass ratio.

CCN06 remains based upon: (1) The long-term post LOCA time of 200,000 seconds, beyond which overpressure is no longer being required, and (2) the containment leakage of 1.5 weight percent per day, to reflect the recently submitted Alternate Source Term (AST) License Amendment Request (Ref: 5, ERC-2004-024)


	VYC-0808, Revision 6, CCN 06		
	ENN-DC-126, Rev 4	MINOR CALCULATION CHANGE	PAGE 3 OF 14


Table of Contents

Cover Page.....	1
Description of Change.....	2
TABLE OF CONTENTS.....	3
1.0 OBJECTIVE.....	4
2.0 METHODOLOGY.....	4
3.0 ASSUMPTIONS.....	4
4.0 ANALYSIS.....	4
4.1 LOCA – SHORT TERM.....	6
4.1.1 Evaluation.....	7
4.2 LOCA – LONG TERM.....	7
4.2.1 Evaluation.....	8
5.0 SUMMARY OF RESULTS.....	9
5.1 LOCA - SHORT TERM (0-600 SEC):	9
5.2 LOCA - LONG TERM (>600 SEC):	9
6.0 CONCLUSIONS	9
TABLE 4.1 LOCA – SHORT TERM (1.5 WT. % CONTAINMENT LEAKAGE & 100% SPRAY EFFICIENCY).....	10
TABLE 4.2 LOCA – LONG TERM (1.5 WT. % CONTAINMENT LEAKAGE & 100% SPRAY EFFICIENCY).....	11
FIGURE 4.2 LOCA – LONG TERM (1.5 WT. % CONTAINMENT LEAKAGE & 100% SPRAY EFFICIENCY).....	14

Note: Figure 4.1 is not contained in this CCN.

Attachment A Excel Verification Sample Calculation.....	6 pages
Attachment B VY Calculation Database Input Form (VY APF0017.07)	2 pages

TOTAL PAGES: 22

	VYC-0808, Revision 6, CCN 06		
	ENN-DC-126, Rev 4	MINOR CALCULATION CHANGE	PAGE 4 OF 14

1.0 Objective

The objective of this CCN is to update the CCN05 (Ref. 12) post LOCA Extended Power Uprate (EPU) evaluation of the adequacy of the available NPSH for the Residual Heat Removal (RHR) and Core Spray (CS) pumps. This includes identification of any change in the amount and duration of suppression pool (torus) overpressure required to maintain adequate NPSH.

Specifically, this CCN06 updates the post LOCA results based on revised containment temperature and pressure profiles provided in Reference 1. The revised containment profiles reflect that the Spray Efficiency used to develop the Reference 1 input is 100%, which resulted in a slight reduction to the pressure profile from CCN05. Additionally, Reference 1 provided revised short-term LOCA data. Therefore, Section 4.1 of CCN04 to VYC-0808 Rev 6 (Ref. 11) is updated to include this data, though the results will be shown to remain unchanged.

2.0 Methodology

General

The methodology for determining the NPSH available (NPSHa) for a given event and temperature is the same as that developed in VYC-0808 Rev 6 and presented in Table 1 of that calculation (Ref: 4). The NPSH required (NPSHr) is also per VYC-0808 Rev 6 and is discussed in detail in Section 4.0 of this CCN. The methodology for determining the pump suction strainer head loss during a LOCA, and the time dependent profile for required overpressure is the same as that developed in CCN04.

3.0 Assumptions

1. None made

4.0 Analysis

As stated in Section 2.0, the methodology for determining the NPSHa is the same as that developed in VYC-0808 Rev 6 and presented in Table 1 of that calculation (Ref: 4). The following terms are used in the evaluation.

$$\text{NPSHa (ft)} = \text{net positive suction head available without overpressure credit} \\ (14.7 - P_g)(144 v_f) + Z - h_f - h_s - h_d$$

where:

Z (ft) = suction elevation head

h_f (ft) = suction line losses


h_s (ft) = clean strainer losses

h_d (ft) = strainer debris losses

P_g (psia) = vapor pressure @ torus temperature

v_f (ft³/lb) = specific volume @ torus temperature and pressure

P_g and v_f are obtained from ASME Steam Tables 1967 Formulation (Ref: 7)

	VYC-0808, Revision 6, CCN 06		
	ENN-DC-126, Rev 4	MINOR CALCULATION CHANGE	PAGE 5 OF 14

NPSHr (ft) = net positive suction head required.

It should be noted that the NPSH required data provided by the pump vendor, as documented in Figures 2.1-1 and 2.2-1 of Attachment 3 to calculation VYC-0808, is actually *Allowable Operating Periods @ NPSHa Specified*. Allowable hours of operation at specified NPSHa values are identified for a range of flows. For this CCN, the NPSHa specified in these Figures is taken as the NPSHr at a given operating time.

Q (gpm) = pump flow rate


OPR (psig) = Overpressure Required
 $(NPSHr - NPSHa) / (144 * Vf)$

For those profile points where there is inadequate NPSH, when considering the suppression pool pressure to be atmospheric (14.7 psia), OPR is the amount of suppression pool pressure required to make NPSHa (ft) equal to NPSHr (ft).

OPA (psig)– Overpressure Available
 The suppression pool pressure available, above atmospheric, for a given event and time.

OPC (psig)– Overpressure Credit Taken
 The overpressure credited in the evaluation of NPSH. Engineering judgement is used to select the credit to be greater than the OPR, by a reasonable amount, and less than the OPA.

Detailed discussion of the above terms is provided in the subsections that follow.

	VYC-0808, Revision 6, CCN 06		
	ENN-DC-126, Rev 4	MINOR CALCULATION CHANGE	PAGE 6 OF 14

4.1 LOCA – Short Term

The temperature and pressure (T/P) profile for the suppression pool during a LOCA is developed in GE-VYNPS-AEP-346R1 (Ref: 1). The short term data is provided from 0-600 seconds.

The evaluation of NPSH is documented in Table 4.1 using the peak pool temperature of 165.1°F which occurs at 600 seconds with a corresponding pool pressure of 17.64 psia. The peak temperature results in the largest vapor pressure and lowest NPSHa. Note that the temperature at lowest pool pressure is 161.2°F / 17.40psia. At this temperature the gain in vapor pressure more than offsets the reduction in pool pressure, therefore the 165.1°F case governs. The details of the evaluation are presented at the top of the Table followed by a matrix of the NPSH results for CS and RHR. Further discussion of selected terms is presented below.

Suction Elevation Head, Z

The values of Z for RHR and CS (12.30' and 12.47' respectively) as calculated in Section 3.5 of VYC-0808 are conservatively used in this evaluation. The suction elevation head is based on the water elevation in the torus. The EPU suppression pool water volume is slightly larger than the existing value used in VYC-0808, which would result in a slight increase in water elevation, and therefore Z.

A water volume comparison at maximum pool temperature is provided below:

	Pre-EPU	EPU
Ref:	(VYC-0808 Rev 6 Section 3.5)	(GE-VYNPS-AEP-346R1)
Short Term	76,800 cuft	79,390 cuft


Maximum Debris Losses (hd)

1 RHR: CCN #3 (Ref: 3) calculated the limiting head loss as 0.24 ft at 181.7°F and 7400 gpm. Note that this is a slight reduction from the head loss (0.33 ft) addressed in Section 3.2 of VYC-0808 Rev 6 (Ref: 4). For conservatism, 0.33 ft at 173°F is used. (Case 1 of Tables 2 and 8 of Ref: 2).

2 RHR: The head loss is taken as .48 ft (Ref: 4) at 170°F (Case 2b of Tables 2 and 8 of Ref: 2) and 14200 gpm.

CS The head loss is conservatively taken as .32 ft (Ref: 4) at 173°F (Case 3d of Tables 2 and 8 of Ref: 2) and 4600 gpm.

Refer to Section 2.0 of CCN04 (Ref. 11) for application of head loss at temperatures other than those used in its calculation.

	VYC-0808, Revision 6, CCN 06		
	ENN-DC-126, Rev 4	MINOR CALCULATION CHANGE	PAGE 7 OF 14

NPRHr - CS

Figure 2.2-1 of Attachment 3 to calculation VYC-0808 provides a plot of *Allowable Operating Periods @ NPSHa Specified* values for various flow rates. This plot shows that at 4600 gpm an allowable NPSH of 28.0 ft is acceptable between 0 and 7 hrs of operation.

NPRHr - 1 RHR

Figure 2.1-1 of Attachment 3 to calculation VYC-0808 provides a plot of *Allowable Operating Periods @ NPSHa Specified* values for various flow rates. This plot shows that at 7400 gpm an allowable NPSH of 23.8 ft is acceptable between 0 and 7 hrs of operation.

NPRHr - 2 RHR

With two RHR pumps operating at a total flow of 14,200 gpm this yields a flow of 7100 gpm per pump.

Also per Figure 2.1-1, the plot shows that at between 0 and 7 hrs of operation, an allowable NPSH of 23.5 ft is acceptable at 7000 gpm and 24.0 ft is acceptable at 7600 gpm.

Interpolating between plotted NPSH values of 23.5 ft @ 7000 gpm and 24.0 ft @ 7600 gpm yields 23.6 ft @ 7100 gpm.

The interpolation equation is developed as documented Section 2.2.2 of VYC-0808 Rev 6 and is $23.0 + (Q - 6400) / 1200$

4.1.1 Evaluation

As can be seen from Table 4.1, there is adequate NPSHa and overpressure is not required.


4.2 LOCA – Long Term

The temperature and pressure (T/P) profile for the suppression pool during a LOCA is developed in GE-VYNPS-AEP-346R1 (Ref: 1). The long term data is provided from 0-864,000 seconds.

The evaluation of NPSH is documented in Table 4.2 using selected T/P points representing the long term profile of the suppression pool. The details of the evaluation are presented at the top of the Table followed by a matrix of the NPSH results for the T/P profile of CS and RHR. The evaluated long term flow rates of 7400 gpm (RHR) and 3500 gpm (CS) are consistent with calculation VYC-0808 Rev 6 (Ref: 4). Further discussion of selected terms is presented below.

Suction Elevation Head, Z

The values of Z for RHR and CS (12.40' and 12.57' respectively) as calculated in Section 3.5 of VYC-0808 are conservatively used in the evaluation. The suction elevation head is based on the water elevation in the torus. The EPU suppression pool water volume is slightly larger than the existing value used in VYC-0808, which would result in a slight increase in water elevation, and therefore Z.

	VYC-0808, Revision 6, CCN 06		
	ENN-DC-126, Rev 4	MINOR CALCULATION CHANGE	PAGE 8 OF 14

A water volume comparison at maximum pool temperature is provided below:

	Pre-EPU	EPU
Ref:	(VYC-0808 Rev 6 Section 3.5)	(GE-VYNPS-AEP-346R1)
Long term	77,640 cuft	79,540 cuft

Maximum Debris Losses (hd)

1 RHR: CCN #3 (Ref: 3) calculated the limiting head loss as 0.24 ft at 181.7°F and 7400 gpm. Note that this is a slight reduction from the head loss (0.33 ft) addressed in Section 3.2 of VYC-0808 Rev 6 (Ref: 4). For conservatism, 0.33 ft at 173°F is used. (Case 1 of Tables 2 and 8 of Ref: 2).

CS: Note that CCN #3 (Ref: 3) documents the up-to-date limiting head loss as 0.19 ft at 181.7°F and 3500 gpm. This is a slight reduction from the head loss (0.21 ft) addressed in Section 3.2 of VYC-0808 Rev 6 (Ref: 4). For conservatism, 0.21 ft at 173°F is used. This is based on a conservative CS flow rate of 4000 gpm. (Case 3b of Tables 2 and 8 of Ref: 2).

NPRHr - CS

Figure 2.2-1 of Attachment 3 to calculation VYC-0808 provides a plot of *Allowable Operating Periods @ NPSHa Specified* values for various flow rates. This plot shows that at 3500 gpm the allowable NPSH increases between 7 and 20 hrs of operation and a value of 29.6 ft is acceptable beyond 20 hrs of operation. This maximum value is conservatively used for the entire long term period (>600 sec).


NPRHr - RHR

Figure 2.1-1 of Attachment 3 to calculation VYC-0808 provides a plot of *Allowable Operating Periods @ NPSHa Specified* values for various flow rates. This plot shows that at 7400 gpm the allowable NPSH increases between 7 and 100 hrs of operation and a value of 31.7 ft is acceptable beyond 100 hrs of operation. This maximum value is conservatively used for the entire long term period (>600 sec).

4.2.1 Evaluation

As can be seen from Figure 4.2 the overpressure required for RHR envelopes that required for CS and the overpressure varies continuously over time. In order to facilitate reporting and presentation of the overpressure required, an enveloping, stepped, overpressure credit is overlaid on Figure 4.2. Refer to Section 4.0 for discussion on selection of overpressure credit.

Though the long term flow rates are postulated at time 600 seconds (e.g. CS throttled down from 4600gpm to 3500gpm), it is not the intent of this calculation to imply at what time throttling should commence or how much throttling is required. This is a function of the time dependent NPSHr and pool temperature. This calculation conservatively evaluates the maximum NPSHr as occurring over the entire operating period (>600 sec). The actual NPSHr is lower between 0-7 hrs and increases after 7 hrs.

	VYC-0808, Revision 6, CCN 06		
	ENN-DC-126, Rev 4	MINOR CALCULATION CHANGE	PAGE 9 OF 14

5.0 Summary of Results

NPSHa is rounded to the nearest 0.1ft and OPR, OPC, and OPA are rounded to the nearest 0.1psig.

5.1 LOCA - Short Term (0-600 sec):

NPSHa is adequate for both CS and RHR pumps without crediting overpressure. NPSHa shown below is at the peak temperature. The results remain unchanged from VYC-0808, Rev. 6, CCN04 (Ref. 11), Section 4.1, LOCA short-term results.

Pump	Total flow, gpm	NPSHr, ft	NPSHa, ft
CS	4,600	28.0	28.4
1RHR	7,400	23.8	31.1
2 RHR	14,200	23.6	28.8

5.2 LOCA - Long Term (>600 sec):

NPSHa is adequate for both CS and RHR pumps with an overpressure credit that varies over time, as shown in Fig. 4.2. NPSHa, OPR, OPC, OPA are shown below, at the peak temperature. The results remain unchanged from VYC-0808, Rev. 6, CCN05 (Ref. 12), LOCA long-term results, except for a slight reduction in Over Pressure Available (OPA).

Pump	Total flow, gpm	NPSHr, ft	NPSHa, ft	OPR, psig	OPC, psig	OPA, psig
CS	3,500	29.6	19.5	4.2	6.1	7.8
1RHR	7,400	31.7	19.6	5.1	6.1	7.8

6.0 Conclusions

Torus overpressure must be credited for 200,000 seconds for operating the RHR and CS pumps at EPU conditions for a long term DBA-Loss of Coolant Accident (LOCA) to achieve adequate NPSH available.

The results of this CCN will provide input to the PUSAR (Ref: 12) for the RHR and CS NPSH evaluation and will alter input to calculation VYC-1628 (Ref: 13) to address the need for crediting torus overpressure in the calculation of NPSH available. Note that calculation VYC-1628 may be superseded by GE EPU Analysis. The need for crediting torus overpressure in the RHR and CS NPSH evaluation, shall also be addressed in the SADBD (Ref: 14), UFSAR (Ref: 15), and system DBDs RHR (Ref: 16) and CS (Ref: 17).

Note that the changes to the UFSAR were originally proposed in CCN04 and CCN05 and are pending incorporation via the design change and licensing processes. This MCC simply updates the previous CCN04 and CCN05 performed under AP-0017. The UFSAR does not currently contain information on containment overpressure.

Note that use of overpressure credit must be approved by the NRC as part of EPU.

No specific 50.59 Screening/Evaluation is required for this CCN since all EPU design changes and associated 50.59 documentation will be part of VYDC-2003-008.



Table 4.1 LOCA – Short Term (1.5 wt. % Containment Leakage & 100% Spray Efficiency)

LOCA - Short Term

NPSHa = $(14.7 \cdot P_g) / (144 \cdot V_f) + Z \cdot h_f \cdot h_s \cdot h_d$
 OPR = $(NPSH_r - NPSH_a) / (144 \cdot V_f)$
 OPA = Over pressure available
 OPC = Over pressure credited

Cross references:

Section 2.3 of VYC-0808 Rev 6 (Ref: 4)
 See Discussion in Section 4.0 of this CCN

Short Term Flow Rate (gpm)

1 RHR Q = 7400 CS Q = 4600
 2 RHR Q = 14200

Table of 1 calc VYC-0808 Rev 6 (Ref: 4)

Suction Line Losses (ft)

1 RHR $h_f = 4.77E-8 \cdot Q^2$ CS $h_f = 2.5E-7 \cdot Q^2$
 2 RHR $h_f = 7.84E-8 \cdot (Q/2)^2$

Section 3.7 of VYC-0808 Rev 6 (Ref: 4)

Clean Strainer Losses (ft)

1 RHR $h_s = 0.33$ CS $h_s = 0.51$
 2 RHR $h_s = 1.22$

Section 3.6 of VYC-0808 Rev 6 (Ref: 4)

Maximum Debris Losses (ft) @ \geq base temperature

1 RHR $h_d = 0.33 @ 173F$ CS $h_d = 0.32 @ 173F$
 2 RHR $h_d = 0.48 @ 170F$

See discussion in Section 4.1 of this CCN
 Ref: 2, 3, 4
 Ref: 2, 4

Maximum Debris Losses (ft) @ $<$ base temperature

1 RHR $h_d = .33^*(173/T)$ CS $h_d = .32^*(173/T)$
 2 RHR $h_d = .48^*(170/T)$

See discussion in Section 2.0 of CCN04 (Ref: 11)

where T = suppression pool temperature, F

Elevation Head (ft)

RHR Z = 12.3 CS Z = 12.47

See discussion in Section 4.1 of this CCN for conservatism.

NPSHr (ft)

1 RHR NPSHr = 23.8 CS NPSHr = 28.0
 2 RHR NPSHr = 23.6

See discussion in Section 4.1 of this CCN

Short Term (After EPU) - Peak Torus Temperature - 1.5 wt. % Containment Leakage & 100% Spray Efficiency

Pump(s)	Time (sec)	GE Pool Temp (F)	GE Pool Pressure psia	Pg (psia)	Vf (ft ³ /lb)	Z (ft)	hf (ft)	hs (ft)	hd (ft)	NPSHa (ft)	NPSHr (ft)	OPR (psig)	OPA (psig)	OPC (psig)
CS	600	165.1	17.64	5.349	0.016423	12.47	5.29	0.51	0.34	28.44	28.00	0.00	2.94	0.00
1 RHR	600	165.1	17.64	5.349	0.016423	12.30	2.61	0.33	0.35	31.12	23.80	0.00	2.94	0.00
2 RHR	600	165.1	17.64	5.349	0.016423	12.30	3.95	1.22	0.49	28.75	23.60	0.00	2.94	0.00


	VYC-0808, Revision 6, CCN 06		
	ENN-DC-126, Rev 4	MINOR CALCULATION CHANGE	PAGE 11 OF 14

Table 4.2 LOCA – Long Term (1.5 wt. % Containment Leakage & 100% Spray Efficiency)

LOCA - Long Term

NPSHa = $(14.7 \cdot Pg)/(144Vf) + Z \cdot hf \cdot hs \cdot hd$
 OPR = Over pressure required $(NPSHr - NPSHa)/(144 \cdot Vf)$
 OPA = Over pressure available
 OPC = Over pressure credited

Cross references:

Section 2.3 of VYC-0808 Rev 6 (Ref: 4)
 See Discussion in Section 4.0 of this CCN

Long Term Flow Rate (gpm)

1 RHR	Q = 7400	CS	Q = 3500	Table of 1 calc VYC-0808 Rev 6 (Ref: 4)
-------	----------	----	----------	---

Suction Line Losses (ft)

1 RHR	hf = $4.77E-8 \cdot Q^2$	CS	hf = $2.5E-7 \cdot Q^2$	Section 3.7 of VYC-0808 Rev 6 (Ref: 4)
-------	--------------------------	----	-------------------------	--

Clean Strainer Losses (ft)

1 RHR	hs = 0.33	CS	hs = $.38 \cdot (Q/4000)^2$ for $Q \leq 4000$	Section 3.6 of VYC-0808 Rev 6 (Ref: 4)
-------	-----------	----	--	--

Maximum Debris Losses (ft) @ $\geq 173F$

1 RHR	hd = 0.33	CS	hd = 0.21	See discussion in Section 4.2 of this CCN
-------	-----------	----	-----------	---

Maximum Debris Losses (ft) @ $< 173F$

1 RHR	hd = $.33 \cdot (173/T)$	CS	hd = $.21 \cdot (173/T)$	See discussion in Section 2.0 of CCN04 (Ref. 11)
-------	--------------------------	----	--------------------------	--

where T = suppression pool temperature, F

Elevation Head (ft)

RHR	Z = 12.4	CS	Z = 12.57	See discussion in Section 4.2 of this CCN for conservatism.
-----	----------	----	-----------	---

NPSHr (ft)

1 RHR	NPSHr = 31.7	CS	NPSHr = 29.6	See discussion in Section 4.2 of this CCN
-------	--------------	----	--------------	---



Table 4.2 LOCA – Long Term (1.5 wt. % Containment Leakage & 100% Spray Efficiency)

CS - Long Term (After EPU) 1.5 wt. % Containment Leakage & 100% Spray Efficiency


Time (sec)	GE Pool Temp (F)	GE Pool Pressure psia	Pg (psia)	Vf (ft ³ /lb)	Z (ft)	hf (ft)	hs (ft)	hd (ft)	CS NPSHa (ft)	CS NPSHr (ft)	CS OPR (psig)	OPA (psig)	OPC (psig)
788	169.7	17.71	5.951	0.016449	12.57	3.06	0.29	0.21	29.73	29.60	0.00	3.01	2.40
1,098	171.8	17.94	6.245	0.016481	12.57	3.06	0.29	0.21	29.05	29.60	0.23	3.24	2.40
2,033	176.6	18.57	6.962	0.016489	12.57	3.06	0.29	0.21	27.38	29.60	0.94	3.87	3.40
2,962	180.0	19.17	7.511	0.016509	12.57	3.06	0.29	0.21	26.10	29.60	1.47	4.47	3.40
4,198	183.4	19.90	8.096	0.016530	12.57	3.06	0.29	0.21	24.73	29.60	2.05	5.20	4.40
5,125	185.2	20.34	8.420	0.016541	12.57	3.06	0.29	0.21	23.96	29.60	2.37	5.64	4.40
6,275	187.0	20.82	8.756	0.016552	12.57	3.06	0.29	0.21	23.17	29.60	2.70	6.12	5.10
8,036	189.1	21.50	9.161	0.016566	12.57	3.06	0.29	0.21	22.22	29.60	3.09	6.80	5.10
10,220	191.0	21.86	9.541	0.016578	12.57	3.06	0.29	0.21	21.32	29.60	3.47	7.16	6.10
12,094	192.2	22.08	9.788	0.016585	12.57	3.06	0.29	0.21	20.74	29.60	3.71	7.36	6.10
15,170	193.6	22.31	10.083	0.016594	12.57	3.06	0.29	0.21	20.04	29.60	4.00	7.61	6.10
17,669	194.3	22.43	10.233	0.016599	12.57	3.06	0.29	0.21	19.68	29.60	4.15	7.73	6.10
20,156	194.6	22.46	10.298	0.016601	12.57	3.06	0.29	0.21	19.53	29.60	4.21	7.76	6.10
23,812	194.7	22.48	10.320	0.016601	12.57	3.06	0.29	0.21	19.48	29.60	4.23	7.78	6.10
24,495	194.7	22.48	10.320	0.016601	12.57	3.06	0.29	0.21	19.48	29.60	4.23	7.78	6.10
25,120	194.7	22.47	10.320	0.016601	12.57	3.06	0.29	0.21	19.48	29.60	4.23	7.77	6.10
30,095	194.3	22.42	10.233	0.016599	12.57	3.06	0.29	0.21	19.68	29.60	4.15	7.72	6.10
35,065	193.7	22.33	10.104	0.016595	12.57	3.06	0.29	0.21	19.99	29.60	4.02	7.63	6.10
40,020	192.8	22.20	9.914	0.016589	12.57	3.06	0.29	0.21	20.44	29.60	3.83	7.50	5.60
45,637	191.5	22.01	9.644	0.016581	12.57	3.06	0.29	0.21	21.08	29.60	3.57	7.31	5.60
49,406	190.4	21.78	9.420	0.016574	12.57	3.06	0.29	0.21	21.61	29.60	3.35	7.08	5.60
60,551	187.2	21.21	8.794	0.016554	12.57	3.06	0.29	0.21	23.09	29.60	2.73	6.51	4.60
70,342	184.4	20.72	8.275	0.016536	12.57	3.06	0.29	0.21	24.31	29.60	2.22	6.02	4.10
80,342	181.8	20.28	7.816	0.016520	12.57	3.06	0.29	0.21	25.38	29.60	1.77	5.58	3.60
90,340	179.3	19.89	7.395	0.016505	12.57	3.06	0.29	0.21	26.37	29.60	1.36	5.19	3.10
100,340	178.8	19.52	6.994	0.016490	12.57	3.06	0.29	0.21	27.30	29.60	0.97	4.82	3.10
110,340	174.8	19.20	6.686	0.016478	12.57	3.06	0.29	0.21	28.02	29.60	0.66	4.50	2.60
120,306	173.2	18.93	6.447	0.016469	12.57	3.06	0.29	0.21	28.58	29.60	0.43	4.23	2.60
130,302	171.8	18.69	6.245	0.016461	12.57	3.06	0.29	0.21	29.05	29.60	0.23	3.99	2.10
140,302	170.4	18.47	6.048	0.016453	12.57	3.06	0.29	0.21	29.51	29.60	0.04	3.77	2.10
150,302	169.1	18.27	5.870	0.016445	12.57	3.06	0.29	0.21	29.92	29.60	0.00	3.57	1.70
160,302	167.8	18.07	5.696	0.016438	12.57	3.06	0.29	0.22	30.31	29.60	0.00	3.37	1.70
170,302	166.6	17.90	5.539	0.016431	12.57	3.06	0.29	0.22	30.67	29.60	0.00	3.20	1.30
180,302	165.3	17.72	5.374	0.016424	12.57	3.06	0.29	0.22	31.05	29.60	0.00	3.02	1.30
190,302	164.1	17.54	5.225	0.016417	12.57	3.06	0.29	0.22	31.40	29.60	0.00	2.84	1.30
194,052	163.6	17.47	5.164	0.016414	12.57	3.06	0.29	0.22	31.54	29.60	0.00	2.77	1.30
196,552	163.3	17.43	5.127	0.016413	12.57	3.06	0.29	0.22	31.62	29.60	0.00	2.73	1.30
197,802	163.2	17.41	5.115	0.016412	12.57	3.06	0.29	0.22	31.65	29.60	0.00	2.71	1.30
200,302	162.9	17.37	5.079	0.016411	12.57	3.06	0.29	0.22	31.73	29.60	0.00	2.67	0.00




Table 4.2 - LOCA - Long Term (1.5 wt. % Containment Leakage & 100% Spray Efficiency)
RHR - Long Term (After EPU) 1.5 wt. % Containment Leakage & 100% Spray Efficiency

Time (sec)	GE Pool Temp (F)	GE Pool Pressure psia	Pg (psia)	Vf (ft ³ /lb)	Z (ft)	hf (ft)	hs (ft)	hd (ft)	RHR NPSHa (ft)	RHR NPSHr (ft)	RHR OPR (psig)	OPA (psig)	OPC (psig)
786	169.7	17.71	5.951	0.016449	12.40	2.61	0.33	0.34	29.84	31.70	0.78	3.01	2.40
1,098	171.8	17.94	6.245	0.016461	12.40	2.61	0.33	0.33	29.17	31.70	1.07	3.24	2.40
2,033	176.6	18.57	6.962	0.016489	12.40	2.61	0.33	0.33	27.50	31.70	1.77	3.87	3.40
2,962	180.0	19.17	7.511	0.016509	12.40	2.61	0.33	0.33	26.22	31.70	2.31	4.47	3.40
4,196	183.4	19.90	8.096	0.016530	12.40	2.61	0.33	0.33	24.85	31.70	2.88	5.20	4.40
5,125	185.2	20.34	8.420	0.016541	12.40	2.61	0.33	0.33	24.09	31.70	3.20	5.64	4.40
6,275	187.0	20.82	8.758	0.016552	12.40	2.61	0.33	0.33	23.30	31.70	3.53	6.12	5.10
8,038	189.1	21.50	9.181	0.016566	12.40	2.61	0.33	0.33	22.34	31.70	3.92	6.80	5.10
10,220	191.0	21.86	9.541	0.016578	12.40	2.61	0.33	0.33	21.44	31.70	4.30	7.18	6.10
12,094	192.2	22.06	9.788	0.016585	12.40	2.61	0.33	0.33	20.86	31.70	4.54	7.36	6.10
15,170	193.6	22.31	10.083	0.016594	12.40	2.61	0.33	0.33	20.16	31.70	4.83	7.61	6.10
17,669	194.3	22.43	10.233	0.016599	12.40	2.61	0.33	0.33	19.81	31.70	4.98	7.73	6.10
20,156	194.6	22.48	10.298	0.016601	12.40	2.61	0.33	0.33	19.65	31.70	5.04	7.78	6.10
23,812	194.7	22.48	10.320	0.016601	12.40	2.61	0.33	0.33	19.60	31.70	5.06	7.78	6.10
24,495	194.7	22.48	10.320	0.016601	12.40	2.61	0.33	0.33	19.60	31.70	5.06	7.78	6.10
25,120	194.7	22.47	10.320	0.016601	12.40	2.61	0.33	0.33	19.60	31.70	5.06	7.77	6.10
30,095	194.3	22.42	10.233	0.016599	12.40	2.61	0.33	0.33	19.81	31.70	4.98	7.72	6.10
35,065	193.7	22.33	10.104	0.016595	12.40	2.61	0.33	0.33	20.11	31.70	4.85	7.63	6.10
40,020	192.8	22.20	9.914	0.016589	12.40	2.61	0.33	0.33	20.56	31.70	4.66	7.50	5.60
45,637	191.5	22.01	9.644	0.016581	12.40	2.61	0.33	0.33	21.20	31.70	4.40	7.31	5.60
49,406	190.4	21.78	9.420	0.016574	12.40	2.61	0.33	0.33	21.73	31.70	4.18	7.08	5.60
60,551	187.2	21.21	8.794	0.016554	12.40	2.61	0.33	0.33	23.21	31.70	3.56	6.51	4.60
70,342	184.4	20.72	8.275	0.016536	12.40	2.61	0.33	0.33	24.43	31.70	3.05	6.02	4.10
80,342	181.8	20.28	7.816	0.016520	12.40	2.61	0.33	0.33	25.50	31.70	2.60	5.58	3.60
90,340	179.3	19.89	7.395	0.016505	12.40	2.61	0.33	0.33	26.49	31.70	2.19	5.19	3.10
100,340	176.8	19.52	6.994	0.016490	12.40	2.61	0.33	0.33	27.43	31.70	1.80	4.82	3.10
110,340	174.8	19.20	6.686	0.016478	12.40	2.61	0.33	0.33	28.14	31.70	1.50	4.50	2.60
120,306	173.2	18.93	6.447	0.016469	12.40	2.61	0.33	0.33	28.70	31.70	1.26	4.23	2.60
130,302	171.8	18.69	6.245	0.016461	12.40	2.61	0.33	0.33	29.17	31.70	1.07	3.99	2.10
140,302	170.4	18.47	6.048	0.016453	12.40	2.61	0.33	0.34	29.62	31.70	0.88	3.77	2.10
150,302	169.1	18.27	5.870	0.016445	12.40	2.61	0.33	0.34	30.03	31.70	0.71	3.57	1.70
160,302	167.8	18.07	5.696	0.016438	12.40	2.61	0.33	0.34	30.43	31.70	0.54	3.37	1.70
170,302	166.6	17.90	5.539	0.016431	12.40	2.61	0.33	0.34	30.79	31.70	0.38	3.20	1.30
180,302	165.3	17.72	5.374	0.016424	12.40	2.61	0.33	0.35	31.16	31.70	0.23	3.02	1.30
190,302	164.1	17.54	5.225	0.016417	12.40	2.61	0.33	0.35	31.51	31.70	0.08	2.84	1.30
194,052	163.6	17.47	5.164	0.016414	12.40	2.61	0.33	0.35	31.65	31.70	0.02	2.77	1.30
196,552	163.3	17.43	5.127	0.016413	12.40	2.61	0.33	0.35	31.73	31.70	0.00	2.73	1.30
197,802	163.2	17.41	5.115	0.016412	12.40	2.61	0.33	0.35	31.78	31.70	0.00	2.71	1.30
200,302	162.9	17.37	5.079	0.016411	12.40	2.61	0.33	0.35	31.84	31.70	0.00	2.67	0.00

Figure 4.2 LOCA – Long Term (1.5 wt. % Containment Leakage & 100% Spray Efficiency)



OPC overpress credit	
(sec)	(psig)
601	2.4
2000	2.4
2001	3.4
4000	3.4
4001	4.4
6000	4.4
6001	5.1
9000	5.1
9001	6.1
40000	6.1
40001	5.6
50000	5.6
50001	5.1
60000	5.1
60001	4.6
70000	4.6
70001	4.1
80000	4.1
80001	3.6
90000	3.6
90001	3.1
110000	3.1
110001	2.6
130000	2.6
130001	2.1
150000	2.1
150001	1.7
170000	1.7
170001	1.3
180000	1.3
200000	1.3
200001	0

	VYC-0808, Revision 6, CCN 06, Attachment A		
	ENN-DC-126, Rev 4	MINOR CALCULATION CHANGE	PAGE 1 OF 6

Excel Verification Sample Calculation

Table 4.1 CS Verification (Line 40):

$$\begin{aligned}\text{Cell G40} &= \$F\$30 \\ &= 12.47\end{aligned}$$

$$\begin{aligned}\text{Cell H40} &= 0.00000025 * \$F\$9^2 \\ &= 0.00000025 * 4600^2 \\ &= 5.29\end{aligned}$$

$$\begin{aligned}\text{Cell I40} &= \$F\$17 \\ &= 0.51\end{aligned}$$

$$\begin{aligned}\text{Cell J40} &= \text{ROUND}(\text{IF}(\text{C40} < 173, 0.32 * (173 / \text{C40}), 0.32), 2) \\ &= 165.1 < 173 = \text{True} \\ &= 0.32 * (173 / \text{C40}) \\ &= 0.32 * (173 / 165.1) \\ &= 0.34\end{aligned}$$

$$\begin{aligned}\text{Cell K40} &= +((14.7 - \text{E40}) * 144 * \text{F40}) + \text{G40} - \text{H40} - \text{I40} - \text{J40} \\ &= ((14.7 - 5.349) * 144 * 0.016423) + 12.47 - 5.29 - 0.51 - 0.34 \\ &= 28.44\end{aligned}$$

$$\begin{aligned}\text{Cell L40} &= \$F\$33 \\ &= 28.00\end{aligned}$$

$$\begin{aligned}\text{Cell M40} &= \text{IF}((+ \text{L40} - \text{K40}) / (144 * \text{F40}) > 0, (+ \text{L40} - \text{K40}) / (144 * \text{F40}), 0) \\ &= (28.00 - 28.44) / (144 * 0.016423) = -0.186 < 0, \text{False} \\ &= 0\end{aligned}$$

$$\begin{aligned}\text{Cell N40} &= + \text{D40} - 14.7 \\ &= 17.64 - 14.7 \\ &= 2.94\end{aligned}$$


	VYC-0808, Revision 6, CCN 06, Attachment A		
	ENN-DC-126, Rev 4	MINOR CALCULATION CHANGE	PAGE 2 OF 6

Table 4.2 CS Table Verification (Line 50):

$$\begin{aligned}\text{Cell F50} &= \$F\$25 \\ &= 12.57\end{aligned}$$

$$\begin{aligned}\text{Cell G50} &= 0.00000025 * \$F\$9^2 \\ &= 0.00000025 * 3500^2 \\ &= 3.06\end{aligned}$$

$$\begin{aligned}\text{Cell H50} &= 0.38 * ((\$F\$9/4000)^2) \\ &= 0.38 * ((3500/4000)^2) \\ &= 0.29\end{aligned}$$

$$\begin{aligned}\text{Cell I50} &= \text{ROUND}(\text{IF}(\text{B50} < 173, \$F\$18 * (173/\text{B50}), \$F\$18), 2) \\ 194.3 < 173 &= \text{False} \text{ (For True outcome see below, Cell I72)} \\ &= \$F\$18 \\ &= 0.21\end{aligned}$$

$$\begin{aligned}\text{Cell I72} &= \text{ROUND}(\text{IF}(\text{B72} < 173, \$F\$18 * (173/\text{B72}), \$F\$18), 2) \\ &= 162.9 < 173 = \text{True} \\ &= \$F\$18 * (173/\text{B72}) \\ &= 0.21 * (173/162.9) \\ &= 0.22\end{aligned}$$

$$\begin{aligned}\text{Cell J50} &= +((14.7 - \text{D50}) * 144 * \text{E50}) + \text{F50} - \text{G50} - \text{H50} - \text{I50} \\ &= ((14.7 - 10.233) * 144 * 0.016599) + 12.57 - 3.06 - 0.29 - 0.21 \\ &= 19.687 \text{ [Worksheet shows 19.68 - Check OK - difference attributed to significant} \\ &\quad \text{figures used in hand calc vs Excel]}\end{aligned}$$

$$\begin{aligned}\text{Cell K50} &= \$F\$28 \\ &= 29.6\end{aligned}$$

$$\begin{aligned}\text{Cell L50} &= \text{IF}((+\text{K50} - \text{J50}) / (144 * \text{E50}) > 0, (+\text{K50} - \text{J50}) / (144 * \text{E50}), 0) \\ (29.6 - 19.68) / (144 * 0.016599) &= 4.15 > 0 \text{ True (For False outcome see below, Cell L34)} \\ &= 4.15\end{aligned}$$

$$\begin{aligned}\text{Cell L34} &= \text{IF}((+\text{K34} - \text{J34}) / (144 * \text{E34}) > 0, (+\text{K34} - \text{J34}) / (144 * \text{E34}), 0) \\ &= (29.6 - 29.73) / (144 * 0.016449) = -0.055 > 0 \text{ False} \\ &= 0\end{aligned}$$

$$\begin{aligned}\text{Cell M50} &= +\text{C50} - 14.7 \\ &= 22.42 - 14.7 \\ &= 7.72\end{aligned}$$


	VYC-0808, Revision 6, CCN 06, Attachment A		
	ENN-DC-126, Rev 4	MINOR CALCULATION CHANGE	PAGE 3 OF 6

Table 4.2 RHR Table Verification (Line 78):

$$\begin{aligned}\text{Cell F78} &= \$C\$25 \\ &= 12.40\end{aligned}$$

$$\begin{aligned}\text{Cell G78} &= 0.0000000477 * \$C\$9^2 \\ &= 0.0000000477 * 7400^2 \\ &= 2.61\end{aligned}$$

$$\begin{aligned}\text{Cell H78} &= \$C\$15 \\ &= 0.33\end{aligned}$$

$$\begin{aligned}\text{Cell I78} &= \text{ROUND}(\text{IF}(\text{B78} < 173, \$C\$18 * (173/\text{B78}), \$C\$18), 2) \\ &169.7 < 173 = \text{True} \text{ (For False outcome see below, Cell I81)} \\ &= \$C\$18 * (173/\text{B78}) \\ &= 0.33 * (173/169.7) \\ &= 0.34\end{aligned}$$

$$\begin{aligned}\text{Cell I81} &= \text{ROUND}(\text{IF}(\text{B81} < 173, \$C\$18 * (173/\text{B81}), \$C\$18), 2) \\ &180 < 173 = \text{False} \\ &= \$C\$18 \\ &= 0.33\end{aligned}$$

$$\begin{aligned}\text{Cell J78} &= +((14.7 - \text{D78}) * 144 * \text{E78}) + \text{F78} - \text{G78} - \text{H78} - \text{I78} \\ &= ((14.7 - 5.951) * 144 * 0.016449) + 12.40 - 2.61 - 0.33 - 0.34 \\ &= 29.84\end{aligned}$$

$$\begin{aligned}\text{Cell K78} &= \$C\$28 \\ &= 31.7\end{aligned}$$

$$\begin{aligned}\text{Cell L78} &= \text{IF}((+\text{K78} - \text{J78}) / (144 * \text{E78}) > 0, (+\text{K78} - \text{J78}) / (144 * \text{E78}), 0) \\ &(31.7 - 29.84) / (144 * 0.016449) = 0.785 > 0 \text{ True (For False outcome see below, Cell L116)} \\ &= 0.785 \quad [\text{Worksheet shows 0.78 - Check OK - difference attributed to} \\ &\quad \text{significant figures used in hand calc vs Excel}]\end{aligned}$$

$$\begin{aligned}\text{Cell L116} &= \text{IF}((+\text{K116} - \text{J116}) / (144 * \text{E116}) > 0, (+\text{K116} - \text{J116}) / (144 * \text{E116}), 0) \\ &= (31.7 - 31.84) / (144 * 0.016411) = -0.059 > 0 \text{ False} \\ &= 0\end{aligned}$$

$$\begin{aligned}\text{Cell M78} &= +\text{C78} - 14.7 \\ &= 17.71 - 14.7 \\ &= 3.01\end{aligned}$$

Excel Verification

VYC-0808 Rev 6
CCN 66
Attachment A Page 4 of 8

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	LOCA - Short Term							Cross references: Section 2.2 of VYC-0808 Rev 6 (Ref. 4) See Discussion in Section 4.0 of this CCN							
2	NPDR =	(14.7 psia(14.7) - 2.44 psia)													
3	OPR =	NPDR - NPDRsp(14.7)													
4	OPA =	Over pressure available													
5	OPC =	Over pressure credit													
6															
7															
8															
9	Short Term Peak Data (cont)							Table of 1 in VYC-0808 Rev 6 (Ref. 4)							
10	1 psia		Q = 7408		CS		Q = 4608								
11	2 psia		Q = 14008												
12	Section 3.7 of VYC-0808 Rev 6 (Ref. 4)							Section 3.7 of VYC-0808 Rev 6 (Ref. 4)							
13	1 psia		M = 4.77E-8°C/s		CS		M = 2.9E-7°C/s								
14	2 psia		M = 7.94E-8°C/s												
15								Section 3.8 of VYC-0808 Rev 6 (Ref. 4)							
16	Direct Structure Loading (R)														
17	1 psia		h _o = 0.33		CS		h _o = 0.31								
18	2 psia		h _o = 1.32					Section 3.8 of VYC-0808 Rev 6 (Ref. 4)							
19															
20	Maximum Direct Loading (R) & Indirect Structure Loading														
21	1 psia		h _d = 0.32 @ 173°F		CS		h _d = 0.32 @ 173°F	See discussion in Section 4.1 of this CCN Ref. 2, 3, 4 Ref. 2, 4							
22	2 psia		h _d = 0.48 @ 173°F												
23															
24	Maximum Direct Loading (R) & Indirect Structure Loading							See discussion in Section 2.8 of CCN (Ref. 11)							
25	1 psia		h _d = .32(173°F)		CS		h _d = .32(173°F)								
26	2 psia		h _d = .48(173°F)												
27	Where T = saturation pool temperature, °F														
28															
29	Elevation Head (R)														
30	1 psia		Z = 12.3		CS		Z = 12.47	See discussion in Section 4.1 of this CCN for conservatism							
31	2 psia														
32															
33	NPDR =							See discussion in Section 4.1 of this CCN							
34	1 psia		NPDR = 23.6		CS		NPDR = 38								
35	2 psia		NPDR = 23.6												
36	Short Term (After EPU) - Peak Torus Temperature - 1.5 wt. % Containment Leakage & 100% Spray Efficiency														
37															
38	Pump(s)	Time (min)	GE Pool Temp (°F)	GE Pool Pressure (psia)	P _g (psia)	W (lbm/s)	Z (ft)	M (lbm)	h _o (ft)	h _d (ft)	NPDR (ft)	NPDR (ft)	OPR (psia)	OPA (psia)	OPC (psia)
40	CS	600	166.1	17.64	5.340	0.016423	~P 530	~0.00000075 1° 39°	~P 517	~PCOUNT(CAS-173.0 32° 173°CAS) 8 35.2)	~P 517	~PCOUNT(CAS-173.0 32° 173°CAS) 8 35.2)	~P 517	~PCOUNT(CAS-173.0 32° 173°CAS) 8 35.2)	~P 517
41	1 psia	600	166.1	17.64	5.340	0.016423	~P 530	~0.00000075 1° 39°	~P 517	~PCOUNT(CAS-173.0 32° 173°CAS) 8 35.2)	~P 517	~PCOUNT(CAS-173.0 32° 173°CAS) 8 35.2)	~P 517	~PCOUNT(CAS-173.0 32° 173°CAS) 8 35.2)	~P 517
42	2 psia	600	166.1	17.64	5.340	0.016423	~P 530	~0.00000075 1° 39°	~P 517	~PCOUNT(CAS-173.0 32° 173°CAS) 8 35.2)	~P 517	~PCOUNT(CAS-173.0 32° 173°CAS) 8 35.2)	~P 517	~PCOUNT(CAS-173.0 32° 173°CAS) 8 35.2)	~P 517

VYC-0808 Rev B
CCN 00
Attachment A Page 8 of 9

[illegible]

VYC-0008 Rev B
CCN #6
Attachment A Page 6 of 9

	A	B	C	D	E	F	G	H	I	J	K	L	M	N
74	RSR - Long Term (After EPU) 1.5 wt. % Contaminant Leakage & 100% Spray Efficiency													
75	Time (min)	Oil Pump Temp (°F)	Oil Pump Pressure (psi)	P _{oil} (psi)	W _{oil} (lb/hr)	Z	M	W	W _{oil} (lb/hr)	W _{oil} (lb/hr)	W _{oil} (lb/hr)	W _{oil} (lb/hr)	W _{oil} (lb/hr)	W _{oil} (lb/hr)
76	75.0545	108.7	17.71	0.761	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
77	1207.85	177.0	17.05	0.245	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
80	3033.388	178.0	18.57	0.882	0.016455	AC328	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
81	3982.323	180.0	18.17	0.711	0.016455	AC328	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
82	4188.46	183.0	18.9	0.285	0.016455	AC328	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
83	5125.04	185.0	20.34	0.121	0.016455	AC328	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
84	5197	187.0	20.7	0.788	0.016455	AC328	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
86	6033.436	189.0	21.5	0.63	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
87	10218.89	191	21.68	0.341	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
87	12083.67	192.0	21.68	0.788	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
88	18169.8	193.0	22.31	0.01	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
89	18169.8	193.0	22.31	0.01	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
90	30184.38	194.0	22.48	0.298	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
91	23381.17	194.0	22.48	0.32	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
92	24494.89	194.0	22.48	0.32	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
93	25118.89	194.0	22.31	0.01	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
94	25118.89	194.0	22.31	0.01	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
95	30084.81	193.0	22.48	0.109	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
96	40290.38	192.0	22.9	0.914	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
97	44437.33	191.0	22.91	0.644	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
98	48406.11	190.0	21.76	0.42	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
99	5177.8	191.0	22.71	0.61	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
100	70342.29	192.0	22.76	0.276	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
101	80332.91	190.0	20.28	0.716	0.016455	AC326	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
102	80332.91	190.0	20.28	0.716	0.016455	AC326	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
103	102336.9	193.0	19.52	0.894	0.016455	AC328	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
104	102336.9	193.0	19.52	0.894	0.016455	AC328	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
105	126030.8	195.0	21.47	0.447	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
106	130302.9	195.0	21.47	0.447	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
107	140528.9	197.0	19.88	0.343	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
108	140528.9	197.0	19.88	0.343	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
109	160022.9	198.0	18.73	0.295	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
110	160022.9	198.0	18.73	0.295	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
111	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
112	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
113	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
114	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
115	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
116	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
117	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
118	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
119	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
120	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
121	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
122	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
123	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
124	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
125	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
126	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
127	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
128	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
129	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
130	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
131	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
132	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
133	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
134	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
135	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
136	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
137	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
138	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318	+0.00000047793299	AC318
139	180022.9	197.0	18.07	0.488	0.016455	AC325	+0.00000047793299	AC318</						

VY CALCULATION DATABASE INPUT FORM

Attachment B Page 1 of 2

Place this form in the calculation package immediately following the Title page or CCN form.

VYC-0808 / 06
 VY Calculation/CCN Number
 Vendor Name: N/A
 Originating Department: Fluid Systems
 Critical References Impacted: ☒ UFSAR ☒ DBD ☐ Reload. "Check" the appropriate box if any critical document is identified in the tables below.
 EMPAC Asset/Equipment ID Number(s): P-10-1A/B/C/D, P-46-1A/B
 EMPAC Asset/System ID Number(s): 10, 14
 Keywords: Residual Heat Removal (RHR), Core Spray (CS), Net Positive Suction Head (NPSH), Loss of Coolant Accident (LOCA), Extended Power Uprate (EPU)

For Revision/CCN only: Are deletions to General References, Design Input Documents or Design Output Documents required? ☐ Yes ☒ No

Design Input Documents and General References - The following documents provide design input or supporting information to this calculation. (Refer to Appendix A, sections 3.2.7 and section 4)

* Reference #	** DOC #	REV #	***Document Title (including Date, if applicable)	Significant Difference Review ††	**** Affected Program	Critical Reference (✓)
1	GE-VYNPS-AEP-346	1	VYNPS EPU T0400: DBA-LOCA for Long Term NPSH evaluation (7/6/04)			
2	VYC-1924	0	DE&S Calc. DC-A34600-006. Vermont Yankee ECCS Suction Strainer Head Loss Performance Assessment, RHR and CS Debris Head Loss Calculations			
3	VYC-0808 / CCN 03	6	Core Spray and Residual Heat Removal Pump Net Positive Suction Head Margin Following a Loss of Coolant Accident			
4	VYC-0808	6	Core Spray and Residual Heat Removal Pump Net Positive Suction Head Margin Following a Loss of Coolant Accident			
5	ERC-2004-024	N/A	Revised OPL-4 Input for Minimum DW Pressure Case dated 6/8/04			
6			NOT USED			
7			ASME Steam Tables, 1967 IFC Formulation for Industrial Use			
8	ERC No. 2003-027	N/A	Debris Source Terms Appropriate for Power Uprate Evaluations of ECCS NPSH (5/13/03)			
9	RHR	1/IC16	Design Basis Document for Residual Heat Removal System			✓
10	VYC-1924 / CCN 02	0	DE&S Calc. DC-A34600-006. Vermont Yankee ECCS Suction Strainer Head Loss Performance Assessment, RHR and CS Debris Head Loss Calculations			
11	VYC-0808 / CCN 04	6	Core Spray and Residual Heat Removal Pump Net Positive Suction Head Margin Following a Loss of Coolant Accident or Anticipated Transients Without Scram			
12	VYC-0808 / CCN 05	6	Core Spray and Residual Heat Removal Pump Net Positive Suction Head Margin Following a Loss of Coolant Accident or Anticipated Transients Without Scram			

Design Output Documents - This calculation provides output to the following documents. (Refer to Appendix A, section 5)

VYC-0808 Revision 6
CCN #6 Attachment B
Page 2 of 2

* Reference #	** DOC #	REV #	Document Title (including Date, if applicable)	**** Affected Program	†††Critical Reference (✓)
12	NEDC-33090P	0	Safety Analysis Report For VYNPS Constant Pressure Power Uprate (PUSAR)		
13	VYC-1628	0	Torus Temperature and Pressure Response to Large Break LOCA and MSLB Accident Scenarios (may be superseded by GE EPU analysis)		
14	SADBD	2/IC2	Topical Design Basis Document for Safety Analysis		✓
15	UFSAR	17	Updated Final Safety Analysis Report		✓
16	RHR	1/IC16	Design Basis Document for Residual Heat Removal System		✓
17	CS	0/IC10	Design Basis Document for Core Spray System		✓

* Reference # - Assigned by preparer to identify the reference in the body of the calculation.

** Doc # - Identifying number on the document, if any (e.g., 5920-0264, G191172, VYC-1286)

*** Document Title - List the specific documentation in this column. "See attached list" is not acceptable. Design Input/Output Documents should identify the specific design input document used in the calculation or the specific document affected by the calculation and not simply reference the document (e.g., VYDC, MM) that the calculation was written to support. If a DBD is used as a general reference, include the most current interim change number after the title.

**** Affected Program - List the affected program or the program that reference is related to or part of.

† If "yes," attach a copy of "VY Calculation Data" marked-up to reflect deletion (See Section 3.1.8 for Revision and 5.2.3.18 for CCNs).

†† If the listed input is a calculation listed in the calculation database that is not a calculation of record (see definition), place a check mark in this space to indicate completion of the required significant difference review. (see Appendix A, section 4.1.4.4.3). Otherwise, enter "N/A."

††† If the reference is UFSAR, DBD or Reload (IASD or OPL), check Critical Reference column and check UFSAR, DBD or Reload, as appropriate, on this form (above).

VYAPF 0017.07
AP 0017 Rev. 8
Page 2 of 2